

Board of Boiler and Pressure Vessel Rules

Meeting Minutes May 7, 2020

Division of Fire Safety

WebEx Board Meeting

Board Members Present

Gary Rogles

William Manes

Bradley Calvin

Kenneth Grissom

Mark Lester

Staff Present

Tim Boggs Deputy Chief

Julie Carey-Senior Office Support Assistant

Gene Reece – State Inspector

Tim Bean – State of Missouri Fire Marshal

Brad Vincent – State Inspector

Brian Hodges – State Inspector

Henry Neurohr – State Inspector

Eric Heitmeyer – State Inspector

Vance Adams -State Inspector

Board Members Absent

Visitor's Present

Mike Clark CEI

Joe Brockman FM Global

Joseph Barbusa -Bayer

Robert Cox - Bayer

Jim Elwood - Bayer

Rick Glenn – DeLong Plumbing

John W DeLong – DeLong Plumbing

Michael Coombs-Travelers

Quentin Coffman-Bayer

Brian Weathers- Starr

John Osseck-Chubb

Mike Whitlock-Hartford

I. Open & Welcome

Meeting was called to order at 9:00 a.m. on May 7, 2020 on WebEx. Roll call was made.

II. Approval of the February 20, 2020 Minutes

Motion was made by Ken Grissom to approve the minutes as written. Brad Calvin seconded the motion. Motion carried to approve the minutes as written.

III. Approval of the May 7th Agenda

Motion was made by Gary Rogles to approve the Agenda as written. Mark Lester seconded the motion.

IV. Chief's Report

Deputy Chief Tim Boggs discussed NBIC 2019 New Codes, Covid 19 Stay Home Order, Insurer Inspections ceased/resuming, State Inspectors, RSMO and 11CSR 40-2's future revisions, The "New Normal"

V. Secretary's Fiscal Summary Report

<u>Fiscal Year 2020</u>	<u>Amount</u>
Total Revenues	\$578,592

VI. New Business

No New Business

VII. Old Business

20-5 Bayer Crop Science – Kansas City, Requesting a variance to change internal inspection intervals from every 1 year to every 2 years.

Motion was made by Gary Rogles to approve the variance. Seconded by Bradley Calvin with the following stipulations:

1. Any changes to the agreed upon letter without specific consent of the Missouri Boiler and Pressure Vessel Board will immediately revoke this variance and Bayer shall return to the annual internal inspections frequency. If Insurance changes the new Insurance Company will be required to agree to these stipulations.

2. The boiler must be inspected by their insurance carrier on a 6 month frequency and a detailed report must be submitted. The report must state that they reviewed their program and it complies with this variance. Our code paragraph 650.260.1 sub paragraph (1) states power boilers and high temperature water boilers shall receive a certificate inspection annually and shall also be externally inspect annually while under pressure if possible.
3. Bayer will present all records during this period to the Boiler Board at the June 2022 (actual date to be determined) for a final review. The Boiler Board will then vote and render its decision whether or not to grant a permanent varianc.

20-9 Enterprise Laundry- Springfield Requesting non recommended clearance.

Motion was made by Bradley Calvin to approve the variance. Seconded by Mark Lester.

VIII. Next Meeting

The next Board of Boiler & Pressure Vessel Rules Meeting will be held on August 13, 2020 at 9:00 a.m. at the Division of Fire Safety, 205 Jefferson, 13th Floor, Jefferson City, Missouri 65102.

IX. Adjournment

Adjourned 9:28AM